



Development Services Department Building Division

SMOKE AND CARBON MONOXIDE ALARMS AFFIDAVIT

DECLARATION OF INSTALLATION IN RESIDENTIAL OCCUPANCIES

FOR COMPLIANCE WITH THE 2016 CALIFORNIA BUILDING CODE (CBC) AND 2016 CALIFORNIA RESIDENTIAL CODE (CRC)
WHERE NO INTERIOR ACCESS IS REQUIRED FOR INSPECTION.

SITE ADDRESS: _____ APN: _____

OWNER: _____ PERMIT#: _____

NUMBER OF ALARMS INSTALLED: SMOKE: _____ CARBON MONOXIDE: _____

When any alterations, repairs or additions requiring a permit occur, or sleeping rooms are created, smoke/carbon monoxide* alarms shall be installed in the following locations (Sections CBC 907.2.11.2, CRC 314.2.2 and CRC 315.2.2):

ROOM/SPACE	SMOKE ALARM REQUIRED? (CBC 907.2.11.2 and CRC R314.3)	CARBON MONOXIDE ALARM REQUIRED? (CRC R315.3)
In each sleeping room	YES	NO
Outside of each separate sleeping area in the immediate vicinity of bedrooms (i.e. hallway)	YES	YES
In each sleeping room with fuel burning appliance	YES	YES
In each story within a dwelling unit, including basements	YES	YES

Carbon Monoxide Alarms are **not** required in dwellings that do not contain fuel-burning appliances and do not have an attached garage.

Multi-Purpose Alarms: Carbon Monoxide Alarms combined with Smoke Alarms shall comply with Section R314.5 and R315.4 of the California Residential Code and shall be approved by the Office of the State Fire Marshall.

Power Supply: In dwelling units with no commercial power supply, alarm(s) may be solely battery operated. In existing dwelling units, alarms are permitted to be solely battery operated where repairs or alterations do not result in the removal of wall and ceiling finishes or there is no access by means of attic, basement, or crawl space. See Sections CBC 907.2.11.9, CRC 314 and CRC 315 of the California Building and California Residential Codes. An Electrical Permit is required for alarms which must be connected to the building wiring.

As owner/contractor of the above-referenced property, I/We affirm and declare that the alarms referenced above have been installed in accordance with the manufacturer's instructions and in compliance with the California Building and California Residential Codes. The alarms have been tested and are operational.

Owner Name: _____ Date: _____

Owner Signature

Contractor Name: _____ Date: _____

Contractor Signature

License #

PROPERTY OWNER AND CONTRACTOR SHALL BOTH SIGN THE AFFIDAVIT FOR DOCUMENT TO BE ACCEPTED